CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE210303007497

Product	Moulded Case Circuit Breaker
Applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Type/Model	NBP-63R
Technical data	Uimp: 6kV;Ui: 690V;Ue: AC230V(1P), AC400V(2P, 3P, 4P);In: 1A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;Over-current release type: Thermal-magnetic;Ics: 7.5kA;Icu: 15kA;Selectivity category: A;Poles: 1P, 2P, 3P, 4P;Suitable for isolation;Rated frequency: 50/60Hz;

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CB2021CQC-100192, the submitted sample(s) of the above item complies with:

EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by themanufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Dec.13,2021

Valid until: Dec.13,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGNATURE: 谢肇煦

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心